

PUBLIC BUILDING COMMISSION OF CHICAGO  
ADDENDUM NO.02 TO CONTRACT NO. 1533R  
For  
EDGEWATER BRANCH LIBRARY (REBID)  
6000 NORTH BROADWAY STREET  
NEW CONSTRUCTION  
PROJECT #08050

DATE: 12/22/2011

**NOTICE OF CHANGES IN CONTRACT DOCUMENTS**

The following changes are hereby made in the Contract Documents.

**Changes to DRAWINGS:**

Change 1: C5.1  
Rewrite 2 call outs to indicate "Raised concrete curb" where curb was previously indicated as cast stone. This revision is for coordination with the other documents in the set.  
Deleted the call out "Ex Traffic signal box to be relocated (by others)". The Traffic signal box has been relocated in site prep phase (by others).  
Modified the call out for Pay station along Broadway. Call out now reads "Ex Pay station removed in Site prep phase and to be reinstated (By others)"

Change 2: S5.3  
Add note to detail 3 and 4 requiring temporary shoring at edge beams.

**QUESTIONS & ANSWERS:**

Q1: Civil Drawings C5.1 calls for a 1" wide x 6" high raised curb in the cast stone around tree pits and to see landscape drawings. Landscape drwg L0.2 calls for 6" high poured in place concrete barrier curb.

A1: Landscape drawings and civil details which show this curb as concrete are correct. The civil note will be updated in an upcoming addendum.

Q2: Were addendums from 1st Edgewater bid included in the Rebid drawings or are we to refer to the old addendums.

A2: Addenda from the original bid are included in the rebid documents.

**List of Attachments:**

DRAWINGS DATED 12/21/11  
Sheet C5.1

Sheet S5.3

**END OF ADDENDUM NO.02**