

PUBLIC BUILDING COMMISSION OF CHICAGO

**ADDENDUM NO. 4 TO CONTRACT NO. C1554
For
WILLIAM JONES COLLEGE PREP HS PHASE II
RENOVATION**

DATE: June 21, 2013

NOTICE OF CHANGES IN CONTRACT DOCUMENTS

The following changes are hereby made in the Contract Documents.

Changes to Book 3: TECHNICAL SPECIFICATIONS:

- Change 1:** Document No. 00 01 10 – Table of Contents (TOC)
- a. **REPLACE** TOC dated 06/19/2013 with TOC dated 06/21/2013 issued herewith.
 - b. Section 05 12 00 – Structural Steel Framing is **ADDED** to TOC as previously issued.

Change 2: Section 05 12 00 – Structural Steel Framing is **NEW**

Changes to Drawings:

- Change 3:** A1.03 – Overall Level 03 Floor Plan / Level 02-Building 'A'
- a. Location of cooling towers and limits of steel grating access platform have been updated and coordinated with existing structural grillage frame.
 - b. Provide 24"x24"x6" high concrete plinth below each access ladder to Cooling Tower Platform. Coordinate with Phase 1 roofing contractor (typical 6 such)
- Change 4:** S6.13 – Building 'D' Structural Modifications for MEP Modifications
- a. Location of cooling towers have been defined and coordinated with existing structural grillage frame.
 - b. Removal of existing steel beams and installation of new steel beams are provided.
- Change 5:** M4.4D –Building D Roof Piping Plan
- a. Location of cooling towers have been defined and coordinated with existing structural grillage frame.
- Change 6:** E2.4D –Building D Roof Electrical Power Plan
- a. Provide weather proof disconnects on cooling towers per motor/equipment schedule.

PUBLIC BUILDING COMMISSION OF CHICAGO

List of Attachments:

SPECIFICATIONS:

<u>Spec. No.</u>	<u>Title</u>	<u>Date</u>	
00 01 10	TABLE OF CONTENTS	06/21/13	
05 12 00	Structural Steel Framing	06/21/13	

DRAWINGS:

<u>Drawing No.</u>	<u>Title</u>	<u>Date</u>	
A1.03	OVERALL LEVEL 03 FLOOR PLAN, LEVEL 02 - BUILDING A	06/21/13	
S6.13	BUILDING D - STRUCTURAL MODIFICATION FOR MECHANICAL UPDATES	06/21/13	
M4.4D	BUILDING D ROOF PIPING PLAN	06/21/13	

END OF ADDENDUM NO.4