

PUBLIC BUILDING COMMISSION OF CHICAGO

ADDENDUM NO. 04 TO CONTRACT NO. 1515

**For
SOUTHWEST AREA HIGH SCHOOL
7651 SOUTH HOMAN AVE
NEW CONSTRUCTION**

DATE: June 21, 2010

NOTICE OF CHANGES IN CONTRACT DOCUMENTS

The following changes are hereby made in the Contract Documents.

Changes to Book 3: TECHNICAL SPECIFICATIONS:

Change 1: Special Audio/Visual System.

Equipment to be furnished by CPS for installation by General Contractor. No allowance is included for Special Audio/Visual System Equipment. Special Audio/Visual System Infrastructure to be furnished and installed by General Contractor as indicated in Contract Documents.

Change 2: Digital Video Surveillance System.

All Products specified at Part 2 of section 16782 will be paid for from the \$500,000 allowance shown on the Bid Form as "CCTV Allowance".

Questions and Answers

Q1: Will the Contractor be allowed to spread excess soils to the parcel to the east?

A1: No. The parcel to the east is not within the Contract limits.

Excavated materials that are not suitable for use within the Contract limits shall be hauled off to a subtitle D landfill.

Spoils due to excavation below sub grade elevations as shown in the Plans and Specifications will be paid at the Unit Prices shown in the Site Work Allowance Schedule.

END OF ADDENDUM NO. 04

Mayor Richard M. Daley, Chairman

Erin Lavin Cabonargi, Executive Director