



**TO:** PROSPECTIVE BIDDERS – CONCRETE FOUNDATIONS

**SUBJECT:** ADDENDUM NO. 3 TO THE BIDDING DOCUMENTS FOR  
**WILLIAM JONES COLLEGE PREPARATORY HIGH SCHOOL – CONCRETE FOUNDATIONS**

**DATE:** March 18, 2011

This Addendum forms a part of the bidding and contract documents and modifies the original bidding documents, plans and specifications released on [March 7, 2011](#). Acknowledge receipt of this addendum in space provided on Bid Form. FAILURE TO DO SO MAY SUBJECT BIDDER TO DISQUALIFICATION.

1. **REMOVE BID PROPOSAL FORM DATED MARCH 4, 2011 AND REPLACE WITH ATTACHED BID PROPOSAL FORM DATED MARCH 18, 2011.**  
  
**\*\*NOTE:** The list of required bid documents has been added to the bid form. Bidders are reminded that all Exhibit T Schedules must be submitted with the bid. Should a Schedule be deemed not applicable to the bidder, mark "N/A" on the Schedule and include in the bid documents. The bid date, time and location have remained as before.
2. **REMOVE THE EXHIBIT T – PBC REQUIRED SUBCONTRACT PROVISIONS DATED FEBRUARY 14, 2011 AND REPLACE WITH THE ATTACHED EXHIBIT T DOCUMENTS INCLUDING ALL SCHEDULES.**
3. **DELETE THE EXHIBIT U - INSTRUCTIONS TO BIDDERS DATED MARCH 4, 2011 IN ITS ENTIRETY. THE INSTRUCTIONS TO BIDDERS HAVE BEEN INCORPORATED IN THE REVISED EXHIBIT T ISSUED IN THIS ADDENDUM.**
4. **BIDDER CLARIFICATION:** In the Exhibit B Scope of Work, item 1.e, the installation of plywood for waterproofing systems is included in this bid. Per the waterproofing specifications, it is NOT necessary for the plywood to be treated. Bidders are to provide adequate thickness of plywood to prevent blowouts of the concrete during installation.
5. **BIDDER CLARIFICATION:** UNIT RATES FOR CONCRETE WILL BE ISSUED UNDER ADDENDUM #4 BY MARCH 22, 2011.

**END OF ADDENDUM #3 -**