

PUBLIC BUILDING COMMISSION OF CHICAGO

**ADDENDUM NO. 1 TO CONTRACT NO. 1522R
FOR
ENGINE COMPANY 16 (REBID)
53 E. PERSHING ROAD
NEW CONSTRUCTION
PROJECT #07060**

DATE: March 24, 2011

NOTICE OF CHANGES IN CONTRACT DOCUMENTS

The following changes are hereby made in the Contract Documents.

Changes to Book 3: TECHNICAL SPECIFICATIONS

- Change 1:** TABLE OF CONTENTS
Section 01001: Delete “consultant” and replace with “coordinator”.
Added new section: “CLEAN CONSTRUCTION OR DEMOLITION DEBRIS AND UNCONTAMINATED SOIL”.
- Change 2:** Section 01001
Entire section: Delete “consultant” and replace with “coordinator”.
- Change 3:** Section 02315
Add New section.
- Change 4:** Section 02316
Added references to new section 02315.
- Change 5:** Section 11020 Fall Arrest Anchor System
Paragraph 1.4D: Delete “professional engineer who is registered and”. Replace with “Structural Engineer who is”.
Paragraph 1.6C: Delete “Professional”. Replace with “Structural”.
Paragraph 1.7C2: Delete “qualified professional”. Replace with “Structural”.
Paragraph 1.9B: Delete “professional”. Replace with “Structural”.
Paragraph 3.3A: Delete “professional”. Replace with “Structural”.

CHANGES TO DRAWINGS

- Change 1:** Sheet SM-1
Added to General Note #4. After, All soils leaving the site “from the Impacted Native or Fill soil areas”
- Added to General Note #6. Second paragraph.
Added to Remediation Note 4. After, All soils leaving the site “from the Impacted Native or Fill soil areas”

Added to Remediation Note 5. After, Native soils within the stippled area "(Impacted)". After,General Note #10 "and project specifications.....".
Impacted Fill gridding area was removed from site drawing and Wabash sidewalk south of site (including planters)
"IMPACTED FILL SOIL OVER NATIVE SOILS BELOW IEPA TACO TIER 1 SROs" was removed from site drawing and Legend
Construction Worker Exceedance location, Legend and like wording from Title Block was removed
In General Note 4. and Remediation Note 4 added "open and active" to "permitted/licensed Subtitle D Landfill".
In Remediation Note 1. added"and non-impacted native soil" to "backfilled with CA-1".
In Remediation Note 3. Paragraph B. was added.
Remediation Note 6. was eliminated.

- Change 2:** Sheet C7.0
Detail 1 revised.
Original Detail 2 deleted.
Balance of details renumbered.
- Change 3:** Sheet C7.2
Detail 2: revised to indicate control joint.
- Change 4:** Sheet A1.1
Tagged control joints along west wall of apparatus bay.
- Change 5:** Sheet A1.2
Tagged control joints along east and west walls of apparatus bay.
- Change 6:** Sheet A1.3
Relocated roof drains on hose tower roof.
- Change 7:** Sheet A4.1
Elevation 54: Added a control joint near grid line 10.5.
- Change 8:** Sheet A6.2
Detail 11: Added note regarding coordination of metal framing with precast.
- Change 9:** Sheet A7.1
Details 51, 53, 35, and 45: Added pipe enclosure for downspout.
Details 51, 53, and 55: Added wall protection plate.
Details 53 and 45: Located unit heater and added a "weather" hood.
- Change 10:** Sheet A7.2
Added Detail 14: Pipe Enclosure.
- Change 11:** Sheet S1.1
Added control joints along west wall of apparatus bay.
- Change 12:** Sheet S1.2
Added control joints along east and west walls of apparatus bay.

- Change 13:** Sheet S1.3
Relocated roof drains on hose tower roof.
Revised note 5 to reflect correct metal deck.
- Change 14:** Sheet S3.1
Detail 9: Added note regarding openings for mechanical penetrations.
- Change 15:** Sheet S4.2
Details 4, 5, 6, 7, and 13: Revised notes to reflect correct metal deck.
- Change 16:** Sheet M1.2
Vehicle exhaust extra drop added .
Hose tower unit heater relocated.
- Change 17:** Sheet M2.1
Hose tower unit heater relocated.
Condensate drain pan added under condensate piping for ACU-1 unit in COMM. ROOM A125
- Change 18:** Sheet M5.1
Air Conditioning Unit Schedule. Note 3 added to read 'PROVIDE EXTENDED STAINLESS STEEL REDUNDANT CONDENSATE DRAIN PAN'
Air Conditioning Unit Schedule remarks column revised to match notes.
- Change 19:** Sheet M6.4
Condensate piping drain pan detail 6 added.
- Change 20:** Sheet E3.1
Moved Fire Alarm Control Panel to column line H wall within Mechanical Room. Location now corresponds to enlarged Mechanical Room plan.
- Change 21:** Sheet P1.2
Relocated roof drain and overflow roof drain, and suspended storm drain piping; matches Architectural plan.
- Change 22:** Sheet P1.3
Relocated roof drain and overflow roof drain to match Architectural plan.
- Change 23:** Sheet P3.1
Detail 11 revised to add clearance note.

List of Attachments:

Specifications

Table of Contents, 01 page (8 1/2"X11" format), dated 03.18.2011
 Section 01001, 02 pages (8 1/2"X11" format), dated 03.18.2011
 Section 02315, 10 pages (8 1/2"X11" format), dated 03.18.2011
 Section 02316, 14 pages (8 1/2"X11" format), dated 03.18.2011
 Section 11020, 06 pages (8 1/2"X11" format), dated 03.18.2011

Drawings

SM-1, 1 page (30"x42" format), dated 03.18.2011
C7.0, 1 page (30"x42" format), dated 03.18.2011
C7.2, 1 page (30"x42" format), dated 03.18.2011
A1.1, 1 page (30"x42" format), dated 03.18.2011
A1.2, 1 page (30"x42" format), dated 03.18.2011
A1.3, 1 page (30"x42" format), dated 03.18.2011
A4.1, 1 page (30"x42" format), dated 03.18.2011
A6.2, 1 page (30"x42" format), dated 03.18.2011
A7.1, 1 page (30"x42" format), dated 03.18.2011
A7.2, 1 page (30"x42" format), dated 03.18.2011
S1.1, 1 page (30"x42" format), dated 03.18.2011
S1.2, 1 page (30"x42" format), dated 03.18.2011
S1.3, 1 page (30"x42" format), dated 03.18.2011
S3.1, 1 page (30"x42" format), dated 03.18.2011
S4.2, 1 page (30"x42" format), dated 03.18.2011
M1.2, 1 page (30"x42" format), dated 03.18.2011
M2.1, 1 page (30"x42" format), dated 03.18.2011
M5.1, 1 page (30"x42" format), dated 03.18.2011
M6.4, 1 page (30"x42" format), dated 03.18.2011
E3.1, 1 page (30"x42" format), dated 03.18.2011
P1.2, 1 page (30"x42" format), dated 03.18.2011
P1.3, 1 page (30"x42" format), dated 03.18.2011
P3.1, 1 page (30"x42" format), dated 03.18.2011

End of Addendum No. 1