

TO: PROSPECTIVE BIDDERS – STRUCTURAL STEEL

SUBJECT: ADDENDUM NO. 5 (REVISED) TO THE BIDDING DOCUMENTS FOR

WILLIAM JONES COLLEGE PREPARATORY HIGH SCHOOL - STRUCTURAL STEEL

DATE: April 25, 2011 \*\*REISSUED WITH CLARIFICATION on 4/26/11\*\*

This Addendum forms a part of the bidding and contract documents and modifies the original bidding documents, plans and specifications released on March 21, 2011. Acknowledge receipt of this addendum in space provided on Bid Form. FAILURE TO DO SO MAY SUBJECT BIDDER TO DISQUALIFICATION.

1. THE BID DATE REMAINS WEDNESDAY, APRIL 27, 2011 AT 11am CST.

BIDS ARE TO BE SUBMITTED LEND LEASE OFFICES AT 1 N WACKER DRIVE, STE 850, CHICAGO, IL

\*\*NOTE: BIDDERS ARE TO USE THE BID FORM DATED 4/14/11 AND WRITE IN THE BID DUE DATE OF WEDNESDAY, APRIL 27, 2011 IN THE UPPER RIGHT HAND CORNER OF THE BID FORM.

2. SEE ATTACHED FINAL RESPONSES TO THE BALANCE OF BIDDERS QUESTIONS THROUGH #47. PREVIOUS RESPONSES TO BIDDERS QUESTIONS INCLUDING SKETCH #SSK-20110413 ARE PUBLISHED FOR CONVENIENCE. \*\*NOTE RESPONSES TO RFIS #23 & #32 HAVE BEEN REVISED. THIS IS THE FINAL ADDENDUM TO THE STRUCTURAL STEEL BIDS.

## \*\*CLARIFICATION: SEE REVISED RESPONSE BELOW TO RFI #28 AS FOLLOWS:

Q: Note 3 on S1.19A called for 2 1/2 "galvanized (G90) acoustical steel deck (18 Ga. Min) with a factory applied, oven baked epoxy intermediate coating at pool." We have been unable to locate a deck manufacturer who produces this profile. Please clarify what alternative deck size/ type should be used in this location.

H+P & DZSE RESPONDS: 2 ½ galvanized (G90) acoustical steel deck (18 Ga. Min) is available from Epic Metals or equal.

- END OF ADDENDUM #5 (revised)-